


# PAT Report Passes And Fails For all Sites and Locations

CLIENT DETAILS	
Company Name:	Nightair Discos
Address:	Unit 1 Eastfield Side Sutton in Ashfield Mansfield Nottinghamshire NG17 4JW



DETAIL OF CONTRACTOR RESPONSIBLE FOR TESTING			
Company Name:	Halls RMS Ltd		
Address:	38 Orchards Way Chesterfield Derbyshire S40 3BZ	Telephone:	01246 222925
		Mobile:	07977 484407
		Email:	dave@halls-electrical.co.uk
Cert Number:		Signature:	
Order Number:			
File Name:	NIGHTAIR.PAT		

## ACCREDITATION DETAILS



PAT TESTER DETAILS			
Serial Number	Make and Model	Certificate Number	Calibration Due Date
02C-0809	Seaward - PrimeTest 350	IH270308	14/03/2016
29D-0657			

## APPLIANCE DETAILS AND TEST RESULTS

Key P = PASS / F = FAIL / S = SKIP (or test not applicable)									
Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (KVA)	Leakage (mA)	Overall Status
<b>NIGHTAIR - NG17 4JW</b>									
19566	MARTIN EFX 500	21/08/15	P	S	P 0.12	P 78.00	S	S	PASS
19567	ABSTRACT TWISTER	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19568	ABSTRACT TWISTER	21/08/15	P	S	P 0.11	P >199	S	S	PASS
19569	UV LIGHT	21/08/15	P	S	P 0.12	P >199	S	S	PASS
19570	VR8	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19571	PARCAN	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19572	PARCAN	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19573	PARCAN	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19574	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19575	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19576	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19577	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19578	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19579	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS

**APPLIANCE DETAILS AND TEST RESULTS**
**Key**  
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
19580	PARCAN	21/08/15	P	S	S	P >199	S	S	PASS
19581	PARCAN	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19582	PS STAR CLOTH	21/08/15	P	S	P 0.05	P >199	S	S	PASS
19583	DMX DISTRIBUTOR	21/08/15	P	S	F 1.60	S	S	S	FAIL
<b>EARTH FAIL</b>									
19584	PARCAN	21/08/15	P	S	P 0.05	P >199	S	S	PASS
19585	PARCAN	21/08/15	P	S	P 0.08	P >199	S	S	PASS
19586	QTX SOUND	21/08/15	P	S	S	P >199	S	S	PASS
19587	CHAUVET	21/08/15	P	S	P 0.04	P >199	S	S	PASS
19588	SOURCE 4 JR	21/08/15	P	S	P 0.08	P >199	S	S	PASS
19589	16A TO IEC	21/08/15	P	S	P 0.05	P >199	S	S	PASS
19590	16A TO IEC	21/08/15	P	S	P 0.03	P >199	S	S	PASS
19591	16A TO IEC	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19592	SOURCE 4 JR	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19593	PSU STAR CLOTH	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19594	TRANSFORMER STAR CLOTH	21/08/15	P	S	P 0.10	P >199	S	S	PASS
19595	MARTIN ACROBAT	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19596	150 FLOOD	21/08/15	P	S	P 0.10	P >199	S	S	PASS
19597	150 FLOOD	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19598	150 FLOOD	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19599	150 FLOOD	21/08/15	P	S	P 0.09	P >199	S	S	PASS
19600	150 FLOOD	21/08/15	P	S	P 0.09	P >199	S	S	PASS
19601	QTX SMARTPAR	21/08/15	P	S	P 0.03	P 106.00	S	S	PASS
19602	QTX SMARTPAR	21/08/15	P	S	P 0.04	P >199	S	S	PASS
19603	QTX SMARTPAR	21/08/15	P	S	P 0.04	P >199	S	S	PASS
19604	SOURCE 4	21/08/15	P	S	P 0.06	P >199	S	S	PASS
19605	SOURCE 4	21/08/15	P	S	P 0.12	P >199	S	S	PASS
19606	SOURCE 4	21/08/15	P	S	P 0.09	P >199	S	S	PASS
19607	SOURCE 4	21/08/15	P	S	P 0.09	P >199	S	S	PASS
19608	SOURCE 4	21/08/15	P	S	P 0.05	P >199	S	S	PASS
19609	SOURCE 4	21/08/15	P	S	P 0.13	P >199	S	S	PASS
19610	150 FLOOD	21/08/15	P	S	P 0.09	P >199	S	S	PASS
19611	SOURCE FLAME LIGHT	21/08/15	P	S	P 0.07	P 138.00	S	S	PASS
19612	SOURCE FLAME LIGHT	21/08/15	P	S	P 0.06	P 26.00	S	S	PASS
19613	SOURCE FLAME LIGHT	21/08/15	P	S	P 0.07	P >199	S	S	PASS
19614	SOUND LAB FLAME	21/08/15	P	S	P 0.04	P 9.00	S	S	PASS
19615	SOUND LAB FLAME	21/08/15	P	S	P 0.03	P 9.30	S	S	PASS
19616	SOUND LAB FLAME	21/08/15	P	S	P 0.04	P 30.00	S	S	PASS
19617	SOUND LAB FLAME	21/08/15	P	S	P 0.02	P 13.80	S	S	PASS
19618	SOUND LAB FLAME	21/08/15	P	S	P 0.01	P 6.70	S	S	PASS
19619	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P 164.00	S	S	PASS
19620	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19621	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19622	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19623	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19624	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19625	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS

**APPLIANCE DETAILS AND TEST RESULTS**
**Key**  
 P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
19626	IEC	21/08/15	P	P	P 0.07	P >199	S	S	PASS
19627	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.12	P >199	S	S	PASS
19628	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19629	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19630	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.04	P >199	S	S	PASS
19631	IEC	21/08/15	P	P	P 0.09	P >199	S	S	PASS
19632	IEC	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19633	IEC	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19634	IEC	21/08/15	P	S	F 0.21	S	S	S	FAIL
<b>EC FAIL</b>									
19635	IEC	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19636	IEC	21/08/15	P	P	P 0.12	P >199	S	S	PASS
19637	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.09	P >199	S	S	PASS
19638	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19639	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.16	P >199	S	S	PASS
19640	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.09	P >199	S	S	PASS
19641	IEC	21/08/15	P	P	P 0.09	P 113.00	S	S	PASS
19642	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.09	P >199	S	S	PASS
19643	IEC	21/08/15	P	P	P 0.05	P >199	S	S	PASS
19644	IEC	21/08/15	P	P	P 0.07	P >199	S	S	PASS
19645	IEC LEG1	21/08/15	P	P	P 0.22	P >199	S	S	PASS
19646	IEC LEG2	21/08/15	P	P	P 0.22	P >199	S	S	PASS
19647	IEC	21/08/15	P	P	P 0.26	P >199	S	S	PASS
19648	IEC	21/08/15	P	P	P 0.12	P >199	S	S	PASS
19649	IEC	21/08/15	P	P	P 0.04	P >199	S	S	PASS
19650	IEC	21/08/15	P	P	P 0.04	P >199	S	S	PASS
19651	IEC	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19652	CLASS 2 LEAD	21/08/15	P	S	S	P >199	S	S	PASS
19653	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19654	POWERCON	21/08/15	P	S	P 0.05	P >199	S	S	PASS
19655	POWERCON	21/08/15	P	P	P 0.14	P 156.00	S	S	PASS
19656	4 GANG EXTENSION LEAD POWERCON	21/08/15	P	P	P 0.14	P 161.00	S	S	PASS
19657	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.15	P >199	S	S	PASS
19658	IEC	21/08/15	P	P	P 0.11	P >199	S	S	PASS
19659	1 GANG EXTENSION LEAD	21/08/15	P	P	P 0.27	P >199	S	S	PASS
19660	IEC	21/08/15	P	P	P 0.08	P >199	S	S	PASS
19661	IEC	21/08/15	P	P	P 0.13	P >199	S	S	PASS
19662	IEC	21/08/15	P	P	P 0.05	P >199	S	S	PASS
19663	IEC	21/08/15	P	P	P 0.25	P 161.00	S	S	PASS
19664	IEC	21/08/15	P	P	P 0.14	P >199	S	S	PASS
19665	IEC	21/08/15	P	P	P 0.25	P >199	S	S	PASS
19666	IEC	21/08/15	P	P	P 0.11	P >199	S	S	PASS
19667	IEC	21/08/15	P	P	P 0.07	P >199	S	S	PASS
19668	4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.11	P >199	S	S	PASS
19669	13A TO 16A LEAD	21/08/15	P	P	P 0.21	P >199	S	S	PASS
19670	16A TO 4 GANG EXTENSION LEAD	21/08/15	P	P	P 0.24	P >199	S	S	PASS

 Total Appliances > **105**

**APPLIANCE DETAILS AND TEST RESULTS**

**Key**  
P = PASS / F = FAIL / S = SKIP (or test not applicable)

Appliance Id	Appliance Description	Test Date	Visual	Polarity	Earth Continuity (Ohms)	Insulation (MOhms)	Load (kVA)	Leakage (mA)	Overall Status
--------------	-----------------------	-----------	--------	----------	-------------------------	--------------------	------------	--------------	----------------

**Total Appliances For Report: 105**